


THE FOLLOWING DIMENSION EQUALS ONE INCH WHEN PRINTED TO SCALE.



HVAC PIPING GENERAL NOTES:

1. THESE DRAWINGS ARE DIAGRAMMATIC, AND REPRESENT THE GENERAL INTENT AND ARRANGEMENT OF SYSTEMS. THEY ARE NOT TO BE CONSIDERED FABRICATION/COORDINATION/SHOP DRAWINGS. COORDINATION WITH OTHER TRADES IS REQUIRED. PROVIDE THE ADDITIONAL FITTINGS AND OFFSETS THAT WILL BE REQUIRED TO COMPLETE EACH SYSTEM AND TO AVOID INTERFERENCES WITH ALL OTHER SYSTEMS INCLUDING THE STRUCTURE, SHEET METAL, OTHER PIPING SYSTEMS, ELECTRICAL CONDUITS, BUS DUCTS, CABLE TRAY, LIGHT FIXTURES, ETC. AND/OR OTHER SPACE CONSTRAINTS.
2. INSTALL SYSTEMS SUCH THAT REQUIRED CLEARANCE AND SERVICE ACCESS SPACE IS PROVIDED AROUND ALL MECHANICAL AND ELECTRICAL EQUIPMENT, AND AROUND ANY COMPONENTS WHICH REQUIRE SERVICE ACCESS.
3. PIPING AND DUCTWORK SHALL NOT BE INSTALLED ABOVE ELECTRICAL TRANSFORMERS, SWITCHBOARDS, PANELBOARDS OR MOTOR CONTROL CENTERS.
4. COORDINATE AND PROVIDE ACCESS DOORS WITHIN INACCESSIBLE CEILING, SHAFT, AND CHASE AREAS FOR ALL COMPONENTS WHICH REQUIRE SERVICE ACCESS. REFER TO ARCHITECTURAL DRAWINGS FOR CEILING TYPES.
5. PROVIDE SUPPLEMENTARY STEEL AS REQUIRED FOR THE PROPER SUPPORT OF ALL SYSTEMS.
6. SUBMIT PROPOSED METHODS OF ANCHORING AND GUIDING PIPING SYSTEMS TO STRUCTURAL ENGINEER FOR APPROVAL.
7. COORDINATE LOCATION OF DUCT-MOUNTED HYDRONIC DEVICES WITH SHEET METAL TRADES.
8. BRANCH PIPING SERVING TERMINAL UNIT HEATING COILS OR RADIANT CEILING PANELS SHALL BE 3/4" UNLESS OTHERWISE NOTED. BRANCH PIPING SERVING MORE THAN ONE TERMINAL UNIT HEATING COIL SHALL BE 1" UNLESS OTHERWISE NOTED. BRANCH PIPING SERVING HOT WATER UNIT HEATERS AND CABINET UNIT HEATERS SHALL BE 1" UNLESS OTHERWISE NOTED.
9. REFER TO TEMPERATURE CONTROLS STANDARD MOUNTING HEIGHTS DETAIL FOR ELEVATIONS OF WALL MOUNTED TEMPERATURE CONTROL DEVICES.
10. STEAM AND CONDENSATE SYSTEMS ARE DESIGNED BASED ON THE ASSUMPTION OF A SUPERVISED WARM-UP PROCEDURE.

CONSTRUCTION KEY NOTES:

1. CONTRACTOR SHALL DRAIN, FLUSH, AND FILL GLYCOL HEATING SYSTEM WITH PRE-MIXED 25% PROPYLENE GLYCOL. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS. THE ESTIMATED SYSTEM VOLUME IS 1,500 GALLONS. CONTRACTOR TO CONFIRM DURING SYSTEM DRAINING PRIOR TO ORDERING OF NEW GLYCOL.



FIRST FLOOR MECHANICAL COMPOSITE PLAN
SCALE: 1/16" = 1' - 0"

REVISION

REVISION



PROJECT TITLE
**MARYSVILLE PUBLIC SCHOOLS
MORTON ELEMENTARY SCHOOL
GLYCOL REPLACEMENT**
920 Lynwood St. Marysville, MI 48040

Not for Construction
SHEET TITLE
**FIRST FLOOR MECHANICAL
COMPOSITE PLAN**
DATE
03/24/2025
ISSUE
CONSTRUCTION
DOCUMENTS
SHEET No.
M0.2

g:\2025\2025-0126-00\CAD\50 - morton es\2025-0126-M0-CMP1.dwg, MD.2, 3/18/2025 9:23:03 AM, Robert W. MacKinnon, Peter Basso Associates Inc.